

LOWNDES COUNTY SCHOOLS
TRANSPORTATION DEPARTMENT REMODEL

ADDENDUM #2

TO: All Bidders

SUBJECT: Transportation Remodel

FROM: Jeff Hill

DATE May 23, 2018

Invitation to bid #042618 for the Lowndes County Schools Transportation Department Remodel is hereby clarified. Amended Bid Form attached.

The following questions were received.

Q1. Addendum #1 – Item no. 2 calls for ADA compliant grab bars for room 112, does room 111 require the grab bars?

A1. No grab bars in room 111. Only room 112.

Q2. Agenda on Pre-Bid conference noted bid time at 10:00 AM and invitation to bid states 2:00 PM, please confirm time.

A2. Bid time is May 29, 2018 at 2:00 PM at the Lowndes County Board of Education office, 1592 Norman Drive, Valdosta, GA 31601.

Q3. Agenda note 4B, relocation of two columns in parts room. Please confirm this is to be included in our scope of work. If yes, please confirm we are only to price moving the two columns and all other work that may be required and engineering will be by the owner.

A3. All work associated with moving the columns is to be included in your scope of work. Owner will provide engineering.

Q4. Should electrical scope of work include replacing all devices and plates?

A4. Yes, replace all devices and plates.

Q5. Can window in room A101 be wood trip and wood stop?

A5. Yes, window in room A101 to be wood trip and wood stop.

Q6. Please confirm extent of mezzanine to receive new 3 1/2 Batt Insulation.

A6. Insulation to be installed underneath the entire mezzanine and in all wood framed walls.

END OF ADDENDUM #2

Attachment 4: Bid Form

BID FORM

Bid #081417 LCBOE Transportation Remodel

Having carefully reviewed the Bid #042618, I submit the following.

Acknowledge: Addendum #1 _____ Addendum #2 _____

BASE BID to complete all work in a workmanlike manner according to standard practices: \$ _____

_____dollars

Company Name & Address: _____

Contractor License Number: _____ County: _____ State: _____

Estimated days to complete upon commencement: _____

Signed: _____

Title: _____